



GRAND COUNTY LOCAL CODE AMENDMENTS  
**LP-GAS APPLIANCE IN PIT OR BASEMENT - G2406.4 (303.7.1)**

Liquefied petroleum gas piping may serve a gas appliance located in a pit, basement or similar location when **all** of the following conditions are met:

- 1) There shall be installed a **listed** gas detector that is interlocked to a **listed** solenoid valve located so as to shut off the supply of gas to the building in the event of an alarm.
- 2) There shall be installed an exhaust system for the purpose of removing unburned gases. The exhaust system shall be interlocked to the gas detector so as to operate automatically in the event of an alarm. The exhaust system shall provide a minimum of four (4) air changes per hour and the exhaust intake shall be located within 6 inches of the floor.

CONTRACTOR: \_\_\_\_\_

PRINT NAME: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_ DATE: \_\_\_\_\_

**BY SIGNING YOU UNDERSTAND THE ABOVE LOCAL CODE AMENDMENT, AND AGREE TO INSTALL ALL LP-GAS EQUIPMENT ACCORDING TO THE CODE REQUIREMENTS AND ACCORDING TO THE MANUFACTURER'S RECOMMENDATIONS.**

PROPERTY OWNER NAME: \_\_\_\_\_

JOB SITE ADDRESS: \_\_\_\_\_

**PROJECT DETAILS:**

APPLIANCES TO BE INSTALLED / REPLACED: PROJECT VALUATION: \$ \_\_\_\_\_

- BOILER \_\_\_\_\_
- FURNACE \_\_\_\_\_
- WATER HEATER \_\_\_\_\_
- GAS FIREPLACE \_\_\_\_\_

EXISTING GAS LINE TO BE UTILIZED  YES  NO\*

EXISTING VENTING TO BE UTILIZED  YES  NO

\* FLOOR PLAN WITH LOCATION OF NEW OR EXTENSION OF GAS LINE INDICATED **IS REQUIRED**

**Please include the manufacturer's installation guidelines with the required minimum clearances**